



# Certificate of Compliance

This certificate is issued for the following:

## Steel Pipe for Automatic Fire Sprinkler Systems

**Pipe Specification**

ASTM A53 / A53M

**Pipe Schedule**

Schedule 40

**Pipe Size**

1/2 through 10 inch NPS  
(21.3 through 273.0 mm NPS)

**Prepared for:**

Saudi Steel Pipe Co. (SSP)  
2<sup>nd</sup> Industrial City  
PO Box 11680  
Dammam 31463  
Kingdom of Saudi Arabia

**Manufactured at:**

Saudi Steel Pipe Co. (SSP)  
2<sup>nd</sup> Industrial City  
PO Box 11680  
Dammam 31463  
Kingdom of Saudi Arabia

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3052515

Approval Granted: January 19, 2016

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the construction as shown in the Approval Guide, an online resource of FM Approvals.

UN-CONTROLLED

David B. Fuller  
AVP, Manager of Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062 USA

